



IKATES, s.r.o.

Tolstého 186, 415 03 Teplice, Czech Republic
Company ID : 25032836

**CERTIFICATION BODY
ISSUES**

CERTIFICATE OF CONFORMITY

No. CQ-6/2022

TO THE APPLICANT : LLC «Stekloluks»
Bazovaya 5, 246020 Gomel, Republic of Belarus

FOR THE PRODUCT: Thermally toughened safety glass

PRODUCER: LLC «Stekloluks»
Bazovaya 5, 246020 Gomel, Republic of Belarus

CONCLUSION / CLASSIFICATION:

Parameters bending strength and fragmentation for thermally toughened safety glass from 4 mm to 12 mm are in agreement with the requirement of standard:

ČSN EN 12150-1+A1:2020 Glass in building – Thermally toughened soda lime silicate safety glass – Part 1: Definition and description

The products are further classified according to the standard:


ČSN EN 12600:2003 Glass in building – Pendulum test – Impact test method and classification for flat glass

**Thermally toughened safety glass thickness 4 mm: EN 12600 1(C)1
Thermally toughened safety glass thickness 10 mm: EN 12600 1(C)1
Thermally toughened safety glass thickness 12 mm: EN 12600 1(C)1**

**Enamelled thermally toughened safety glass thickness 4 mm: EN 12600 1(C)0
Enamelled thermally toughened safety glass thickness 5 mm: EN 12600 1(C)3
Enamelled thermally toughened safety glass thickness 6 mm: EN 12600 1(C)3
Enamelled thermally toughened safety glass thickness 8 mm: EN 12600 1(C)3
Enamelled thermally toughened safety glass thickness 10 mm: EN 12600 1(C)2
Enamelled thermally toughened safety glass thickness 10 mm: EN 12600 1(C)2**

Certificate has been issued on the basis of the Test reports No. 297/2021 of the testing laboratory No. 1139 IKATES, s.r.o., Teplice, accredited by ČIA. Rules for the use of certificate are adduced on the second side of this certificate.

Date of issue : 2022-01-28
Validity till: 2025-01-28




Lubomír Hnilička
Manager of the Certification Body